

## Seasonal Pavilion/Lodge Rental Variations (Oct. 15 – April 15) at Wingfoot Lake State Park

- Concession Facilities will be closed (some close after Labor Day weekend)
- The central restroom facility will be the only facility open.
- Access to facilities must be verified with the office (330-628-4720, option 3) the week prior to the reservation.
- Items moved from the structure must be returned to their location at the conclusion of your rental (year round).
- Per park policy and the information from the Ohio Fire Code, any portable heater with an "open flame" is prohibited within pavilions/lodges. Electric (ideally radiant) heaters that are directly plugged into the outlet (no extension cords) and with automatic shut off capability if tipped are permissible. Please keep in mind that the fuse will "trip" with overloading which may impact your ability to use and enjoy the facility.

### **Ohio Administrative Code 1301:7 Division of State Fire Marshal**

#### **Chapter 1301:7-7 Ohio Fire Code**

#### **1301:7-7-06 Building services and systems.**

##### (C) Section 603 Fuel-fired appliances

(4) 603.4 Portable unvented heaters. Portable unvented fuel-fired heating equipment shall be prohibited

##### (E) Section 605 Electrical equipment, wiring and hazards

(10) 605.10 Portable, electric space heaters. Where not prohibited by other paragraphs of this code, portable, electric space heaters shall be permitted to be used in all occupancies other than Group I-2 and in accordance with paragraph (E)(10)(a)(605.10.1) to (E)(10)(d)(605.10.4) of this rule.

Exception: The use of portable, electric space heaters in which the heating element cannot exceed a temperature of 212°F (100°C) shall be permitted in nonsleeping staff and employee areas in Group I-2 occupancies.

(a) 605.10.1 Listed and labeled. Only listed and labeled portable, electric space heaters shall be used.

(b) 605.10.2 Power supply. Portable, electric space heater shall be plugged directly into an approved receptacle.

(c) 605.10.3 Extension cords. Portable, electric space heaters shall not be plugged into extension cords.

(d) 605.10.4 Prohibited areas. Portable, electric space heaters shall not be operated within 3 feet (914 mm) of any combustible materials. Portable, electric space heaters shall be operated only in locations for which they are listed.